



Vehicle  
Certification  
Agency



Maritime &  
Coastguard  
Agency



Department  
for Transport



VCA Dangerous Goods Office  
Cleeve Road, Leatherhead  
Surrey, KT22 7NF, UK  
T +44 (0)1372 226110  
F +44 (0)1372 226116  
E dgenquiries@vca.gov.uk  
www.dft.gov.uk/vca

# CERTIFICATE OF PACKAGING PERFORMANCE

Issued on behalf of the Department for Transport, Civil Aviation Authority and the Maritime and Coastguard Agency by the VCA Dangerous Goods Office

Certificate serial number: 4907

**NOT TRANSFERABLE**

Application No.: 5820

Issue number and date: 06 04/12/2019

Issued to: **FUEL PROOF LTD**  
Middleton Business Park  
Middleton Road  
Heysham  
Lancashire  
LA3 3FH

Packaging type: 31A Description:  
**Rigid, steel intermediate bulk container  
for liquids**

Capacity: 2000 litres

Tare: 788

No of Entry Points: 2

Top Lift: Yes

Contents: Tested with water for liquids

Fully welded cylindrical steel container housed, 3mm thickness, housed within steel cylindrical bund, 4mm thickness, with internal fittings consisting of baffle wall. Closure: 1 x 2" & 1 x 3" steel BSP pipes fitted with Al 2" & 3" caps with rubber gaskets, torque 30Nm. Discharge: 1" BSP threaded socket fitted with 1" chrome plated brass level ball valve, connected to hose and nozzle via pump. Pressure relief: 1 x 1/4" BSP pressure relief valve & 1 x 1" BSP check valve.

Special Notes: Issued in accordance with multilateral agreement M229

It is certified that a sample of the design type described above has been tested in accordance with the provisions of the United Nations Recommendations on the Transport of Dangerous Goods, Chapter 6.5 and appropriate paragraphs from 6.5.6.4 to 6.5.6.9 and successfully met the criteria. IBCs of the design type tested may bear the marking:



**31A/Z/\*\* \*\*/GB/FUEL PROOF - 4907/0/2560**

\*\* \*\* To be replaced by the month and the last two digits of the year of manufacture

**THE TEST REPORT(S) AND ITS APPENDICES ARE AN INTEGRAL PART OF THIS DOCUMENT**

The additional marking specified in 6.5.2.2 subject to pressure limitation as in 4.1.1.10 must be applied to each serially produced IBC.

When permitted by national or modal regulations, IBCs of the design type described may be used for liquids.

DROP HEIGHT (m)	0.8	packing group	relative density (d)	gross mass (kg)
STACK HEIGHT	0 High	I	-	-
INTERNAL PRESSURE (kPa)	200	II	-	-
LEAKPROOFNESS (kPa)	20	III	0.84	2468

**Revalidation due by: 31/12/2024**

For further details see [www.vca.gov.uk](http://www.vca.gov.uk)

Signed:

*E. J. Girling*

Keith F B White, Acting Head of Dangerous Goods VCA DGO